

**Thermoplastic LED Exit Sign
AC, AC/DC or Self-Powered**

IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be taken including the following:

**READ AND FOLLOW ALL SAFETY
INSTRUCTIONS**

1. Do not use outdoors.
2. Do not let power supply cords touch hot surfaces.
3. Do not mount near gas or electric heaters.
4. Equipment should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
5. The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
6. Do not use this equipment for other than intended use.
7. All servicing should be performed by qualified service personnel.

SAVE THESE INSTRUCTIONS

Installation Instructions

1. Turn off AC power.
2. Route AC unswitched circuit of rated voltage into electrical box and leave 6" of wire length.
3. Remove the exit door using a coin or a screwdriver at the top or bottom of the door.
4. Determine the mounting position (end, wall or ceiling). Note: canopy is required for end or ceiling mount.

Wall mounting

- a. No canopy required. With the help of a flat head screwdriver, knock out the proper hole pattern in the back cover to mount to a standard junction box (See Fig. 2). Feed the AC supply leads out through the center hole and make the proper connections (See step 5 and Fig 6). Feed the excess wire into the junction box and secure the back cover to the junction box using the junction box screws. Proceed to step 6.

End or ceiling mount

- a. Canopy required. Attach the spider plate to electrical box with the junction box screws. Remove appropriate hole plug. Feed AC supply leads through side or top opening and then through canopy. Remove the canopy lock(12) (if supplied). Snap canopy on top or side of frame (See Fig. 3). Re-install the canopy lock (if supplied). Screw canopy to frame(11). In the case where a canopy lock is supplied, you may refrain from screwing the canopy to the frame. However, for applications having a greater risk of exposure to abnormal impacts, we suggest to always use the canopy housing screw(11) (fig. 1 and 3). Make the proper wire connections. The "Quick-install" canopy is equipped with ribs allowing you to hang the unit on the spider plate to facilitate wiring (See fig.4). Feed the excess wire into the junction




Figure 1

Part List

1. Back plate
2. Frame
3. Diffuser panel
4. Exit door
5. Hole plug for Canopy
6. Canopy
7. Junction box screws (not provided)
8. Spider plate
9. Junction box
10. Canopy plate screw
11. Canopy housing screw
12. Canopy lock




Figure 2




Figure 3




Figure 3




Figure 2




Figure 1

Description des pièces

1. Dos de la boîte de jonction (non fournis)
2. Boîtier de l'enseigne
3. Diffuseur de couleur
4. Face de l'enseigne
5. Bouton d'obturation
6. Socle
7. Vis de la boîte de jonction
8. Plaque de fixation
9. Boîte de jonction
10. Vis de montage sur plaque
11. Vis de fixation du socle
12. Cle de blocage du socle

5. Notre système peut recevoir un courant de 120 VCA, 277 VCA ou 347 VCA. Raccorder le fil noir (120 VCA), orange (277 VCA) ou rouge (347 VCA) et le fil blanc (neutre) à l'alimentation de l'édifice et ce pour toutes les orientations de montage. Note: pour l'option à deux circuits, il y aura deux paires de fils à raccorder. Raccorder le fil vert à la M.A.L.T.

⚠ Les fils primaires non utilisés doivent être isolés de façon à éviter un court-circuit (See Fig.6).

- Enlever la ou les flèche(s) amovible(s) de la face de l'enseigne. En tentant celle-ci de vos deux mains, pousser la flèche amovible vers l'extérieur à l'aide d'un doigt ou d'un tournevis. Il se peut que vous ayez à soulever le couvercle de la batterie pour effectuer cette tâche.
- Réinstaller la ou les faces(s) de l'enseigne.
- Réactiver le courant CA et l'enseigne s'allumera.

Modèles CA/CC

Se reporter au câblage CA et CC de la figure 6.
Pour la portion CC Raccorder le fil rouge (+) à la tension d'entrée CC positive et le fil noir (-) à la tension d'entrée CC négative.
 Remarque : la plage de tension d'arrivée CC est de 6 à 48 volts.

Modèles auto-alimentés

Test manuel
 Appuyer sur le bouton d'essai. L'enseigne clignotera mais restera allumée et le voyant CA s'éteindra. Le voyant s'allume lorsque le relai d'interrupteur et le chargeur automatique rechargent l'accumulateur à sa pleine capacité. Pour les modèles avec option de diagnostic automatique, le voyant DEL externe clignotera pour indiquer l'alarme (voir tableau ci-joint).

Test et diagnostic automatique (optionnel)
 Les modèles auto-alimentés avec diagnostic automatique comprennent un microcontrôleur qui effectue mensuellement un test et affiche les défauts des composants électriques : batterie, chargeur d'accumulateur, lampes (DEL).

Test automatique
 L'appareil effectuera un test de 1 minute tous les mois, un test de 10 minutes tous les 6 mois et un test complet de décharge de 30 minutes à tous les 12 mois.






Diagnostic automatique
 Un DEL vert externe clignote si une alarme est détectée (voir fig. 7), ce qui signifie que l'unité devra être inspectée.

	Allumé	CA sous tension
0	Vert	Clignote
-0	Vert	Allumé
0	Rouge	Batterie déconnectée
-0	Rouge	Clignote 1 fois
0-0	Rouge	Défaut de batterie
0-0-0	Rouge	Clignote 2 fois
0-0-0-0	Rouge	Clignote 4 fois
		Défaut de DEL

Entretien

Aucun entretien n'est requis. Si l'alimentation CA doit être débranchée pendant un délai de 2 mois, l'accumulateur doit être débranché (modèles auto-alimentés seulement).

Remarque
 Les modèles auto-alimentés de type NiCd (Nickel Cadmium) sont préchargés et peuvent nécessiter 10 minutes de raccordement à une alimentation CA avant la procédure de test de mise en marche et 96 heures pour atteindre une charge complète ou 24 heures pour atteindre une charge suffisante pour permettre une décharge de 30 minutes.



Maintenance
 None required. If AC supply to the unit is to be disconnected for 2 months or more, the battery must be disconnected. Self-Powered Models only.
Noté (Nickel Cadmium) batteries are shipped discharged and may require 10 minutes of connection to AC supply before start-up test procedure, and 96 hours to reach full charge

	Green	Steady On	AC On
0	Green	One Blink	In Test
0	Red	Steady On	Battery Disconnect
-0	Red	One Blink	Battery Failure
0-0	Red	Two Blinks	Charger Failure
0-0-0-0	Red	Four Blinks	LED Strip Failure

Diagnostic function
 The diagnostic function uses an external green LED indicator. Service is required if the green LED blinks indicating that an alarm condition is detected (See Fig. 7).
Self-test
 The self-test is performed every 30 days for 1 minute, every 6 months for 30 minutes, and annually for 90 minutes.

Manual testing
 Press test switch. Legend will flicker, but remain lit. On release, external green LED will illuminate, and automatic charger will restore battery to full charge. For AD models the LED will blink (see table below).
Automatic testing and diagnostics, optional
 The models with the automatic testing and diagnostic option include a micro-controller which self-tests the unit on a monthly basis and identifies as well displays failures of the electrical components: battery, battery charger, lamps, LEDs.

Self-Powered Models

AC/DC Models
 Refer to Fig. 6 for AC & DC wiring.
For DC portion Wire the Red lead (+) to the positive DC input voltage and the Blue Lead (-) to the negative DC input voltage. Note: DC input voltage range is 6 volts to 48 volts.

- Unused primary wire must be insulated to prevent shorting (See Fig.6).
- Remove the appropriate chevron(s) on the exit door by holding sign with both hands. Push chevrons from the inside with thumb (See Fig. 5). You may need to unstrap the diffuser panel to do so.
- Connect the battery.
- Reinstall exit door(s).
- Energize AC. Sign will illuminate.

- Remove the appropriate chevron(s) on the exit door by holding sign with both hands. Push chevrons from the inside with thumb (See Fig. 5). You may need to unstrap the diffuser panel to do so.
- Connect the battery.
- Reinstall exit door(s).
- Energize AC. Sign will illuminate.

box. Unhook unit and slide ribs on canopy into designated notches on the spider plate (See Fig. 4). Secure the canopy to the junction box using the canopy screw(s) provided(10).
 5. Our system can accept input voltages of 120 VAC, 277 VAC or 347 VAC. Therefore, connect the black (120 VAC) or orange (277 VAC) or red (347 VAC) and white (common) leads to the building utility. Note: for dual circuit option, there will be two sets of wires.
 Connect the Green wire to the ground.